

TÜV SÜD  
 ZERTIFIKAT ◆ CERTIFICATE ◆ CERTIFICADO ◆ CERTIFIKAT ◆ 認證證書 ◆ CERTIFICATE ◆ CERTIFIKAT ◆ CERTIFICATE



# CERTIFICATE

No. Z1A 012906 0507 Rev. 00

**Holder of Certificate:** **DÜPERTHAL SICHERHEITSTECHNIK GMBH & Co. KG**



Frankenstraße 3  
63791 Karlstein  
GERMANY

**Factories:** 062099

**Certification Mark:**



**Product:** **Safety cabinets**  
**Model(s):** CLASSIC line , COMPACT line

**Parameters:**

CLASSIC line		COMPACT line	
model type (standard and pro)	approx. size (width x height x depth in mm)	model type	approx. size (width x height x depth in mm)
S	594 x 1385 x 612	SL	594 x 1385 x 747
SL	594 x 1385 x 747	ML	594 x 2045 x 747
XS	1194 x 1385 x 612	LL	894 x 2045 x 747
M	594 x 2045 x 612	XXL	1650 x 2045 x 747
ML	594 x 2045 x 747		
L	894 x 2045 x 612		
LL	894 x 2045 x 747		
XL	1194 x 2045 x 612		
XXL	1650 x 2045 x 747		

Fire resistance class of the safety cabinets: FWF 90.  
 A detailed description of the specifications can be found in the test report.

**Tested according to:** DIN EN 14470-1:2004  
 DIN EN 16121:2017  
 DIN EN 16122:2012  
 EK5/AK4 09-10:2009  
 TRGS 510:2013 Anlage 3  
 AfPS GS 2014:01 PAK

The product meets the safety and health requirements of the German Product Safety Act section 20 to 22 ProdSG. The certification marks shown above can be affixed on the product. It is not permitted to alter the certification marks in any way. In addition the certificate holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. See also notes overleaf.

**Test report no.:** 713155294  
**Valid until:** 2024-11-06

**Date,** 2019-12-04 ( Horst Kristen )

