



Product Service

CERTIFICATE

No. Z1 17 11 12906 253

**Holder of Certificate: DÜPERTHAL SICHERHEITSTECHNIK
GMBH & Co. KG****DÜPERTHAL**Frankenstraße 3
63791 Karlstein
GERMANY**Production
Facility(ies):** 62099**Certification Mark:****Product:** Safety cabinets
Model(s): BATTERY line, 69-HHBBT7-xyz(ss)
Parameters: Key code Art.-No.

HH	Height, stands for number 13, 20
BB	Width, stands for number 06, 09, 12
T	Depth stands for number 6
x	Colour, stands for number 0, 1, 4, 5, 6, 7
yz	Interior fitting, stands for number 00-99
ss	Special sign, stands for L, A, U, B, R, D, S, T

Fire resistance: FWF 90

The article number defines exact material and size of the single product. A full description of the specifications is provided in the test report.

Tested according to: DIN EN 14470-1:2004
DIN 14727:2006
EK5/AK4 09-10:2009
DIN 31000:2017

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: 713105424
Valid until: 2022-11-08**Date,** 2017-11-17 (Horst Kristen)

Page 1 of 1

